



# MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

**FELTOUCH YAPI TASARIM SAN. TİC.A.Ş OF**  
**ISTANBUL, TURKEY** 09 B BLOCK NO. 7/15 ®

Category:  
Cert. Scheme:

Construction Material - Wall Panel  
VOC Emissions

Accredited  
Standards &  
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

\*Conforms  
With:

LEED v4.1 ID+C, BD+C  
(CHPS) 2019 Core Criteria EQ C6.1.6  
Criteria of MAS Certified Green® Program  
TVOC Emissions at 14-days

low-emitting interiors  
ceiling & wall systems  
low-emitting material  
0.5 mg/m<sup>3</sup> or less

Bracketed  
Products:

Wall Panel Plates: 6mm Plate, 7mm Plate, DecoSound, Flatline.

Test Date:

8/26/2019

Report No.: 1901066

Certificate No.: MAS1901066R1

valid August 2019 to August 2020



Testing Cert. # 2925.01  
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

\*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>