



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

DURO DYNE CORP. OF BAY SHORE, NY

81 SPENCE STREET, ZIP CODE: 11706



Category:

Construction Materials - Interior Adhesives, Glues, Sealants & Coatings

Cert. Scheme:

VOC Emissions

Accredited
Standards &
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms
With:

LEED v4.1 ID+C, BD+C
CHPS 2019 Core Criteria 3.0 EQ C6.1.1
Criteria of MAS Certified Green® Program
TVOC Emissions at 14-days

low-emitting materials
adhesives & sealants
low-emitting material
0.5 mg/m³ or less

Bracketed
Products:

RPG Low VOC

Test Date:

August 6, 2020 Report No.:2000448 Certificate No.: MAS2000448-02-1DD

valid August 2020 to August 2021



Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Testing Cert. # 2925.01
Product Cert. # 2925.02

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>