



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

**H.B. FULLER CONSTRUCTION PRODUCTS, INC. OF
DALTON, GA** 1702 KIMBERLY PARK DR.; ZIP CODE: 30721

Category:
Cert. Scheme:

Construction Materials - Flooring Systems
VOC Emissions

Accredited
Standards &
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms
With:

LEED v4.1 ID+C, BD+C
CHPS 2019 Core Criteria 3.0 EQ C6.1.2
Criteria of MAS Certified Green® Program
TVOC Emissions at 14-days
low-emitting material
flooring systems
low-emitting material
0.5 mg/m³ or less

Bracketed
Products:

Underlayment: TEC® Level Set® 200**, TEC® Level Set® 300, TEC® Level Set® Deep Pour 3, TEC® EZ Level®, TEC® Contractor Grade Self-Leveling Underlayment, TEC® Level Set® LW-60, CHAPCO® Standard SLU, CHAPCO® Premium SLU & TEC® Skill Set® Ultimate Self-Leveling Underlayment.

**Product tested as representative exemplar for products listed above.

Test Date:

September 9, 2020 Report No.:2000511 Certificate No.: MAS2000511-02

valid September 2020 to September 2021



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>