



# MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

## DAYTON SUPERIOR CORP. OF MIAMISBURG, OH

1125 BYERS ROAD; ZIP CODE: 45342

Category:  
Cert. Scheme:

Construction Materials - Concrete Finishing Products  
VOC Emissions

Accredited  
Standards &  
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

\*Conforms  
With:

LEED v4.1 ID+C, BD+C  
CHPS 2019 Core Criteria 3.0 EQ C6.1.5  
Criteria of MAS Certified Green® Program  
TVOC Emissions at 14-days

low-emitting materials  
paints & coatings  
low-emitting materials  
0.5 mg/m<sup>3</sup> or less

Compliant  
Products:

Level Primer J42RTU

Test Date:

November 20, 2020 Report No.:2000639 Certificate No.:MAS2000639-02-3

valid: November 2020 to November 2021



Testing Cert. # 2925.01  
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

\*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>