



# MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

**H.B. FULLER CONSTRUCTION PRODUCTS, INC.**  
**OF DALTON, GA** 1702 KIMBERLY PARK DRIVE; ZIP CODE: 30721

Category:  
Cert. Scheme:

Construction Materials - Flooring Systems  
VOC Emissions

Accredited  
Standards &  
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

\*Conforms  
With:

Criteria of MAS Certified Green® Program	low-emitting materials
LEED v4.1 ID+C, BD+C	low-emitting materials
LEED TVOC Emissions at 14-days	0.5 mg/m <sup>3</sup> or less
CHPS 2019 Core Criteria 3.0 EQ C6.1.1	adhesive & sealants
CHPS 2019 Core Criteria 3.0 EQ C6.1.5	paints & coatings

Certified  
Products:

Floor Patch and Levelers: TEC®VersaPatch® Latex Modified Floor Patch, CHAPCO® QDP Plus, CHAPCO® Patch, CHAPCO® SmoothFinish, TEC® Perfect Finish™ Skim Coat, TEC® Fast-Set Deep Patch, TEC® Floor Patch Pro\*\*, TEC® Feather Edge Skim Coat.      \*\* Product tested as representative exemplar of products listed above.

Test Date:

March 5, 2021      Report No.:2100055      Certificate No.: MAS2100055-02

Valid: March 2021 to March 2022



Testing Cert. # 2925.01  
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT  
Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012  
\*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>