

MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **HERCULES INDUSTRIES, INC. OF DENVER, CO**
1310 W. EVANS AVENUE; ZIP CODE: 80223

Category: Construction Materials - Interior Adhesives, Glues, Sealants & Coatings
Cert. Scheme: VOC Emissions, VOC Content

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 classroom & private office adhesive & sealant applications
SCAQMD Rule 1168 (**VOC Content)

*Conforms With: Criteria of MAS Certified Green® Program low-emitting materials
LEED v4.1 ID+C, BD+C (VOC Emissions & Content) low-emitting materials
LEED TVOC Emissions at 14-days 0.5 mg/m³ or less
CHPS 2019 Core Criteria 3.0 EQ C6.1.1 adhesives & sealants

Certified Products: Duct Liner Adhesives:
MTA500, MTA600, MTA600W***, MTA600-HV, MTA600W-HV.

(*** Product tested as representative exemplar of products listed above.)

Test Date: March 31, 2021 Report No.: 2100135 Certificate No.: MAS2100135-01

Valid: April 2021 to April 2022



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

**Laboratory Testing by RTI Labs, Livonia MI, 48150 - ISO/IEC 17025:2017 (#0570.02)

Laboratory Testing by Materials Analytical Services, LLC - ISO/IEC 17025:2017 Page 1 Of 1

3rd Party Product Certification by MAS Certified Green® - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>