

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **ARMACELL, LLC OF CHAPEL HILL, NC**
55 Vilcom Center Drive, Suite 200; Zip Code: 27514

Category: Construction Materials - Interior Adhesives, Glues, Sealants & Coatings
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program
LEED v4.1 ID+C, BD+C *low-emitting materials*
LEED TVOC Emissions at 14-days *low-emitting materials*
CHPS 2019 Core Criteria 3.0 EQ C6.1.1 *0.5 mg/m³ or less*
adhesives & sealants

Certified Product: 520 BLV Adhesive

Test Date: September 01, 2021 Report No.:2100554 Certificate No.: MAS2100554-02-1

Valid: September 2021 to September 2022



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>