

# MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **FLOOR SEAL TECHNOLOGY, INC. OF MILPITAS, CA**  
1005 AMES AVENUE; ZIP CODE: 95035

Category: Construction Materials - Interior Paints, Finishes & Coatings  
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

\*Conforms With: Criteria of MAS Certified Green® Program  
LEED v4.1 ID+C, BD+C *low-emitting materials*  
LEED TVOC Emissions at 14-days *low-emitting materials*  
CHPS 2019 Core Criteria 3.0 EQ C6.1.5 *0.5 mg/m<sup>3</sup> or less*  
*paints & coatings*

Certified Products: MirrorCrete Finishing Aid

Test Date: October 25, 2021 Report No.: 2100728R1 Certificate No.: MAS2100728R1-01FST-01

Valid: October 2021 to October 2022



Testing Cert. # 2925.01  
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012  
\*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>