



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to: **OMNOVA SOLUTIONS INC. OF AKRON, OH**
2990 GILCHRIST ROAD; ZIP CODE: 44305

Category: Interior Construction Material - Wallcovering
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 classroom settings

*Conforms With: Criteria of MAS Certified Green® Program
CHPS 2019 Core Criteria 3.0 EQ C6.1.6
LEED v4.1 ID+C, BD+C
TVOC Emissions at 14-days
low-emitting materials ceiling & wall systems
low-emitting materials 0.5 mg/m3 or less

Certified Products: 3D Laminate Wallcovering

Test Date: October 5, 2021 Report No.:2100624-03R1 Certificate No.: MAS2100624-03R1-2

Valid: October 2021 to October 2022



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>