

MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **H.B. FULLER CONSTRUCTION PRODUCTS, INC. OF
AURORA, IL** 1105 SOUTH FRONTENAC STREET; ZIP CODE: 60504

Category: Construction Materials - Adhesives, Sealants & Coatings
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office (duct systems only)*

*Conforms With: LEED v4.1 ID+C, BD+C (classroom & office setting) *low-emitting materials*
CHPS 2019 Core Criteria 3.0 EQ C6.1.1 *adhesives & sealants*
Criteria of MAS Certified Green® Program *low-emitting materials*
TVOC Emissions at 14-days *0.5 mg/m³ or less*

Certified Products: Group 1: Vapor Retarder Coatings: 30-33, 30-65, 30-80, 30-80AF, 30-90, CP-33, CP-34**, CP-35, CP-38, G-353.

**Product tested as representative exemplar of product bracket listed above.

Test Date: September 27, 2022 Report No.:2200790 Certificate No.: MAS2200790-R1

Valid: September 2022 to September 2023



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>