

MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **SKY ACOUSTICS INC., OF ONTARIO, CANADA**
55 Bradwick Drive, Concord, Ontario L4K 1K5 Canada

Category: Construction Material - Ceiling and Wallcovering
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office (as ceiling panel)*
California Dept. of Public Health Standard Method v1.2 *classroom (as wall panel)*

*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*
LEED v4.1 ID+C, BD+C *low-emitting materials*
LEED TVOC Emissions at 14-days *0.5 mg/m³ or less*
CHPS 2019 Core Criteria 3.0 EQ C6.1.6 *ceiling & wall systems*

Certified Products: Fabric Covered Acoustical Panels: *Aura, Baffles, Nexus, Stratus**, SuperCluster.*

** Product tested as representative exemplar of products listed above.
Includes all available fabric options.

Test Date: December 14, 2021 Report No.: 2100894 Certificate No.: MAS2100894R1

Valid: December 2021 to December 2022



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>