

MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **TNEMEC COMPANY, INC. OF NORTH KANSAS CITY, MO**
123 WEST 23RD AVENUE; ZIP CODE: 64116

Category: Construction Materials - Interior Adhesives, Glues, Sealants & Coatings
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program
LEED v4.1 ID+C, BD+C *low-emitting materials*
LEED TVOC Emissions at 14-days *low-emitting materials*
classroom - 0.5 mg/m³ or less
CHPS 2019 Core Criteria 3.0 EQ C6.1.5 *private office - 0.5 to 5.0 mg/m³*
paints & coatings

Certified Products: Solventborne Products Series Bracket
(see page 2 for list of certified products)

Test Date: October 17, 2022 Report No.: 2200808R3 Certificate No.: MAS2200808R3-01.3

Valid: October 2022 to October 2023



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 2

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>

MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **TNEMEC COMPANY, INC. OF NORTH KANSAS CITY, MO**

123 WEST 23RD AVENUE; ZIP CODE: 64116

Certified Products:

Series AK02 Tnemec Universal Primer
Series 2E13 Hypoglaze
Series 44-710 Urethane Accelerator
Series 44-713 Urethane Accelerator
Series L69 Hi-Build Epoxoline II
Series L69F Hi-Build Expoxoline II
Series 94-H20 Hydro-Zinc[#]
Series 135 Chembuild
Series 247 EverThane^{**}
Series 248 EverThane
Series 249ESD Static-Shield UR
Series 394 PerimePrime[#]

Solventborne Products Bracket

Series 690 Siloxilon
Series V700 HydroFlon
Series V701 HydroFlon
Series 740 UVX
Series 750 UVX
Series 1070V Fluoronar
Series 1071V Fluoronar
Series 1072V Fluoronar
Series 1074 Endura-Shield II
Series 1074U Endura-Shield II
Series 1075 Endura-Shield II
Series 1075U Endura-Shield II
Series L140 Pota-Pox Plus
Series 1078V Fluoronar Metallic
Series 1079 Metallic Clearcoat
Series 1079-0762 Metallic Clearcoat
Series 1079-0763 Metallic Clearcoat
Series 1090 Excella-Shield DTM
Series 1091 Excella-Shield DTM
Series 1094 Endura-Shield
Series 1095 Endura-Shield
Series 1096 Endura-Shield
Series N1094 Endura-Shield
Series N1095 Endura-Shield
Series N1096 Endura-Shield

All color options are covered under this certification

^{**}Product tested as representative exemplar of products listed above. [#]Color options not available.

Test Date: October 17, 2022

Report No.: 2200808R3

Certificate No.: MAS2200808R3-01.3

Valid: October 2022 to October 2023



Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017

3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>

Page 2 Of 2