

MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **MAAX BATH INC. OF LACHINE, QUEBEC**
160 Saint-Joseph Blvd; H8S 2L3

Category: Construction Material - Wallcovering
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program
Criteria of MAS Certified Green® Program
LEED v4.1 ID+C, BD+C
LEED TVOC Emissions at 14-days
*low-emitting materials
single family residence (2 showers)
low-emitting materials
0.5 mg/m³ or less*

Certified Products: *MAAX Bath Shower Base*

Test Date: July 20, 2023 Report No.: 2300470 Certificate No.: MAS2300470

Valid: July 2023 to July 2024



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>