

# MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **H.B. FULLER CONSTRUCTION PRODUCTS, INC. OF  
AURORA, IL** 1105 SOUTH FRONTENAC STREET; ZIP CODE: 60504

Category: Construction Materials - Adhesives, Sealants & Coatings  
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office (duct systems only)*

\*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*  
LEED v4.1 ID+C, BD+C (classroom & office setting) *low-emitting materials*  
TVOC Emissions at 14-days *0.5 mg/m<sup>3</sup> or less*  
CHPS 2019 Core Criteria 3.0 EQ C6.1.5 *paints & coatings*

Certified Products: Group 1: Vapor Retarder Coatings: 30-33, 30-65, 30-80, 30-80AF, 30-90, CP-33, CP-34, CP-35\*\*, CP-38, CP-38 AF.

\*\*Product tested as representative exemplar of product bracket listed above.

Test Date: October 23, 2023 Report No.:2300637 Certificate No.: MAS2300637-01R1

Valid: October 2023 to October 2024



Testing Cert. # 2925.01  
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

Page 1 Of 1

\*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>