

# MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **H.B. FULLER CONSTRUCTION PRODUCTS, INC. OF  
AURORA, IL** 1105 SOUTH FRONTENAC STREET; ZIP CODE: 60504

Category: Construction Materials - Adhesives, Sealants & Coatings  
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

\*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*  
LEED v4.1 ID+C, BD+C (classroom & office setting) *low-emitting materials*  
LEED TVOC Emissions at 14-days *0.5 mg/m<sup>3</sup> or less*  
CHPS 2019 Core Criteria 3.0 EQ C6.1.1 *adhesives & sealants*

Certified Products: Group 5: Adhesives #1: 85-00, 85-00 Black, 85-10, 85-10 Black, 85-60\*\*, 85-62, 85-65, 85-70, 97-15, CP-125, CP-126, CP-127 & CP-127-2.

\*\*Product tested as representative exemplar of product bracket listed above.

Test Date: October 23, 2023 Report No.:2300637 Certificate No.: MAS2300637-05R1

Valid: October 2023 to October 2024



Testing Cert. # 2925.01  
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

\*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>