

MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **AL MUQARRAM INSULATION MATERIAL INDUSTRY, LLC**
OF UNITED ARAB EMIRATES

P.O. BOX 24756, SHARJAH – UAE

Category: Construction Materials - Sealants
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program
LEED v4.1 ID+C, BD+C *low-emitting materials*
LEED TVOC Emissions at 14-days *low-emitting materials*
LEED TVOC Emissions at 14-days *<0.5 mg/m³ (classroom)*
CHPS 2019 Core Criteria 3.0 EQ C6.1.1 *0.5 - 5.0 mg/m³ (private office)*
adhesives & sealants

Certified Products: Dolphin Sealant Products Bracket
(see page 2 for list of certified products)

Test Date: April 04, 2024 Report No.: 2400138 Certificate No.: MAS2400138

Valid: April 2024 to April 2025



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

Page 1 Of 2

*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. 30024 · 770-866-3200 · <http://www.mascertifiedgreen.com/>

MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **AL MUQARRAM INSULATION MATERIAL INDUSTRY, LLC**
OF UNITED ARAB EMIRATES P.O. BOX 24756, SHARJAH – UAE

Certified Products:

Dolphin Sealant Products Bracket

<i>Dolphin 105 Glass and Aluminum Silicone Sealant</i>	<i>Dolphin 110 Aquarium Silicone Sealant</i>	<i>Dolphin 120 High Temperature Silicone Sealant</i>	
<i>Dolphin 125 Universal Silicone Sealant</i>	<i>Dolphin 135 Bath, Kitchen & Plumbing Silicone Sealant</i>	<i>Dolphin 140 GP Silicone Sealant</i>	
<i>Dolphin 200 GP PRO Silicone Sealant</i>	<i>Dolphin 500 Sanitary & Construction Silicone Sealant</i>	<i>Dolphin 510 Sanitary & Construction Silicone Sealant</i>	
<i>Dolphin 530 Façade, ACP & Curtain Walls Silicone Sealant</i>	<i>Dolphin 540 Doors and Windows Silicone Sealant</i>	<i>Dolphin 1200G GP Silicone Sealant</i>	
<i>Dolphin Acryseal Acrylic</i>	<i>Dolphin Cornice Adhesive</i>	<i>Dolphin Ducting Acrylic</i>	
<i>Dolphin Exterior Acrylic</i>	<i>Dolphin Fire Stop Acrylic**</i>	<i>Dolphin Fire Stop Silicone Sealant</i>	
<i>Dolphin Fix & Seal All Purpose</i>	<i>Dolphin Fix & Seal Power</i>	<i>Dolphin Fix & Seal Super Clear</i>	
<i>Dolphin PowerBond Instant Grab</i>	<i>Dolphin PowerBond Multi-Purpose</i>	<i>Dolphin PU45</i>	<i>Dolphin Windscreen Fix</i>

** Product tested as representative exemplar of products listed above

Test Date: April 04, 2024

Report No.: 2400138

Certificate No.: MAS2400138

Valid: April 2024 to April 2025



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 2 Of 2

3945 Lakefield Ct. · Suwanee, Ga. 30024 · 770-866-3200 · <http://www.mascertifiedgreen.com/>