



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to: **MON-ECO INDUSTRIES, INC.**
5 Joanna Court; East Brunswick, NJ 08816

Category: Construction Materials - Interior Adhesives, Glues, Sealants & Coatings
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*
LEED v4.1 ID+C, BD+C *low-emitting materials*
LEED TVOC Emissions at 14-days *0.5 mg/m³ or less*
CHPS 2019 Core Criteria 3.0 EQ C6.1.1 *adhesives & sealants*

Certified Products: Eco-Duct Sealants: 44-39 Eco-Duct® Seal, 44-50 Eco-Duct® Seal, 44-52 Eco-Duct® Seal**, 44-52 Eco-Duct® Low VOC, 48-81 Eco-Duct® Seal.

**Product tested as representative exemplar of products listed above.

Test Date: April 05, 2024 Report No.: 2400188 Certificate No.: MAS2400188-02

Valid: April 2024 to April 2025



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope