

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **HERCULES INDUSTRIES, INC.**
1310 W. EVANS AVENUE, DENVER, CO 80223

Category: Construction Materials - Interior Adhesives, Glues, Sealants & Coatings
Cert. Scheme: VOC Emissions, VOC Content

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office adhesive & sealant applications*
SCAQMD Rule 1168 (**VOC Content)

*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*
LEED v4.1 ID+C, BD+C (VOC Emissions & Content) *low-emitting materials*
LEED TVOC Emissions at 14-days *0.5 mg/m³ or less*
CHPS 2019 Core Criteria 3.0 EQ C6.1.1 *adhesives & sealants*

Certified Products: Duct Sealants:
*MTS100, MTS200, MTS300, MTS300-W***, MTS400, MTS500.*

(*** Product tested as representative exemplar of products listed above.)

Test Date: July 26, 2024 Report No.:2400451 Certificate No.: MAS2400451-02

Valid: August 2024 to August 2025



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

**Laboratory Testing by [ATS Labs, Marietta GA, 30062](#) - ISO/IEC 17025:2017 (#1888.02)

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017 Page 1 Of 1

3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. 30024 · 770-866-3200 · <http://www.mascertifiedgreen.com/>