

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **FERGUSON ENTERPRISES**
751 Lakefront Commons; Newport News, VA 23606

Category: Construction Material - SMC/CMC Surround Walls
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office (as wallcoverings)*

*Conforms With: Criteria of MAS Certified Green® Program
Criteria of MAS Certified Green® Program
LEED v4.1 ID+C, BD+C
LEED TVOC Emissions at 14-days
CHPS 2019 Core Criteria 3.0 EQ C6.1.6
*low-emitting materials
single family residence (2 showers)
low-emitting materials
0.5 mg/m³ or less
ceiling & wall systems*

Certified Products: SMC/CMC Walls: *Classic Wall Kit and NexTile Wall Kit with or without FHA backing.*

Test Date: August 16, 2024 Report No.: 2400502 Certificate No.: MAS2400502-01FE.1

Valid: August 2024 to August 2025



Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. • Suwanee, Ga. 30024 • 770-866-3200 • <http://www.mascertifiedgreen.com/>