

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **SOLAR GARD® SAINT GOBAIN**
4540 VIEWRIDGE AVENUE, SAN DIEGO, CA: 92123

Category: Construction Materials - Thermal Window Films
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*
LEED v4.1 ID+C, BD+C *low-emitting materials*

Certified Products: Solar Gard® Window Films with Pressure Sensitive Adhesive**
Solar Gard® Safety Window Films with Pressure Sensitive Adhesive
Solar Gard® Anti-Graffiti/Vandalism Window Films with Pressure Sensitive Adhesive

** Product tested as representative exemplar of products listed above.

Test Date: October 29, 2024 Report No.:2400652 Certificate No.: MAS2400652

Valid: October 2024 to November 2025



Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. · Suwanee, Ga. 30024 · 770-866-3200 · <http://www.mascertifiedgreen.com/>