

# MAS Certified Green® Certificate of Compliance

## Low-Emitting Materials



Awarded to: **DURO DYNE NATIONAL CORPORATION**  
81 SPENCE STREET, BAY SHORE, NY 11706

Category: Construction Materials - Interior Adhesives, Glues, Sealants & Coatings  
Cert. Scheme: VOC Emissions, VOC Content

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*  
SCAQMD Rule 1168 (\*\*VOC Content) *adhesive & sealant applications*

\*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*  
LEED v4.1 ID+C, BD+C (VOC Emissions & Content) *low-emitting materials*  
LEED TVOC Emissions at 14-days *0.5 mg/m³ or less*  
CHPS 2019 Core Criteria 3.0 EQ C6.1.1 *adhesives & sealants*

Certified Products: Duct Liner Adhesives: WIT5LVAS, BWITLVAS & WIT50HS

Test Date: July 26, 2024      Report No.:2400451      Certificate No.: MAS2400451-01DD.R1

**Valid: August 2024 to August 2025**



Testing Cert. # 2925.01  
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

\*\*Laboratory Testing by [ATS Labs, Marietta GA, 30062](#) - ISO/IEC 17025:2017 (#1888.02)

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017

Page 1 Of 1

3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

\*outside of A2LA accreditation scope

3945 Lakefield Ct. • Suwanee, Ga. 30024 • 770-866-3200 • <http://www.mascertifiedgreen.com/>