

# MAS Certified Green® Certificate of Compliance

## Low-Emitting Materials



Awarded to: **H.B. FULLER CONSTRUCTION PRODUCTS, INC.**  
1105 SOUTH FRONTENAC ROAD, AURORA, IL 60504

Category: Construction Materials - Adhesives, Sealants & Coatings  
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office (duct systems only)*

\*Conforms With: Criteria of MAS Certified Green® Program  
LEED v4.1 ID+C, BD+C (classroom & office setting) *low-emitting materials*  
TVOC Emissions at 14-days *low-emitting materials*  
CHPS 2019 Core Criteria 3.0 EQ C6.1.5 *less than 0.5 mg/m<sup>3</sup>*  
*paints & coatings*

Certified Products: Group 1: Vapor Retarder Coatings: 30-33, 30-65, 30-80, 30-80AF\*\*, 30-90, CP-33, CP-34, CP-35, CP-38 & CP-38 AF.

\*\*Product tested as representative exemplar of product bracket listed above.

Test Date: December 5, 2024 Report No.:2400678R1 Certificate No.: MAS2400678R1-01R2

**Valid: December 2024 to December 2025**



Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012  
\*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. • Suwanee, Ga. 30024 • 770-866-3200 • <http://www.mascertifiedgreen.com/>