

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **H.B. FULLER CONSTRUCTION PRODUCTS, INC.**
1105 SOUTH FRONTENAC ROAD, AURORA, IL 60504

Category: Construction Materials - Adhesives, Sealants & Coatings
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program
LEED v4.1 ID+C, BD+C *low-emitting materials*
LEED TVOC Emissions at 14-days *low-emitting materials*
CHPS 2019 Core Criteria 3.0 EQ C6.1.5 *0.5 mg/m³ or less*
paints & coatings

Certified Products: Group 6: IAQ Coatings: 40-11, 40-20, 40-20C, 40-25, 40-25A, 40-30**, 40-30C, 40-50, G-371.

**Product tested as representative exemplar of product bracket listed above.

Test Date: December 5, 2024 Report No.:2400678R1 Certificate No.: MAS2400678R1-06

Valid: December 2024 to December 2025



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. · Suwanee, Ga. 30024 · 770-866-3200 · <http://www.mascertifiedgreen.com/>