

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **OMNOVA A DIVISION OF SURTECO**
2990 GILCHRIST ROAD, AKRON, OH 44305

Category: Interior Construction Material - Wallcovering
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *private office & classroom*

*Conforms With: Criteria of MAS Certified Green® Program
LEED v4.1 ID+C, BD+C
TVOC Emissions at 14-days
CHPS 2019 Core Criteria 3.0 EQ C6.1.6
*low-emitting materials
low-emitting materials
0.5 mg/m³ or less
ceiling & wall systems*

Certified Products: Group 1: 007-CP-012 & 007-CP-013**
Boltaflex Coated Fabric as Wallcovering

** Product tested as representative exemplar for the products listed above.

Test Date: February 17, 2025 Report No.: 2500032 Certificate No.: MAS2500032-01B

Valid: February 2025 to February 2026



Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. • Suwanee, Ga. 30024 • 770-866-3200 • <http://www.mascertifiedgreen.com/>