

# MAS Certified Green® Certificate of Compliance

## Low-Emitting Materials



Awarded to: **OMNOVA A DIVISION OF SURTECO**  
2990 GILCHRIST ROAD, AKRON, OH 44305

Category: Interior Construction Material - Wallcovering  
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom setting*

\*Conforms With: Criteria of MAS Certified Green® Program  
LEED v4.1 ID+C, BD+C  
TVOC Emissions at 14-days  
CHPS 2019 Core Criteria 3.0 EQ C6.1.6  
*low-emitting materials*  
*low-emitting materials*  
*0.5 mg/m<sup>3</sup> or less*  
*ceiling & wall systems*

Certified Products: Group 2: 007-CP-050\*\*, 007-CP-051 & 007-CP-161  
*Boltaflex Coated Fabric as Wallcovering*

\*\* Product tested as representative exemplar for the products listed above.

Test Date: February 17, 2025    Report No.: 2500032    Certificate No.: MAS2500032-02B

**Valid: February 2025 to February 2026**



Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012

\*outside of A2LA accreditation scope

3945 Lakefield Ct. • Suwanee, Ga. 30024 • 770-866-3200 • <http://www.mascertifiedgreen.com/>