

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **AEROFLEX USA, INC.**

282 INDUSTRIAL PARK ROAD, SWEETWATER, TN 37874

Category: Construction Materials - Exterior/Interior** Adhesives, Glues, Sealants & Coatings
Cert. Scheme: VOC Content & VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2
South Coast Air Quality Management District Rule 1168 *classroom & private office
low VOC content-adhesives
& sealant applications*

*Conforms With: Criteria of MAS Certified Green® Program *low VOC content & emissions materials*
LEED v4.1 ID+C, BD+C *low VOC content & emissions materials*
LEED TVOC Emissions at 14-days *0.5 mg/m³ or less*
CHPS 2019 Core Criteria 3.0 EQ C6.1.1 *adhesives & sealants*
(low VOC content & low VOC emissions)
Material VOC Content *(less water & less exempt compounds)* *19.0 g/L*

Certified Products: Aeroseal LVOC Adhesive

Test Date: February 21, 2025 (VOC content) Report No.:2500081 Certificate No.:MAS2500081-01R2
April 2, 2025 (VOC emissions)

Valid: February 2025 to April 2026



Testing Cert. # 2925.01
Product Cert. # 2925.02

Kevin Simpson

Product Certifier, MAS Certified Green CT

Page 1 Of 1

Lab VOC content Testing by **Applied Technical Services, LLC** - ISO/IEC 17025:2017 (A2LA cert. #1888.02)
Lab VOC emissions testing & 3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

**Compliance designation determined based on interior modeling scenarios and interior VOC Emissions guideline requirements.

3945 Lakefield Ct. • Suwanee, Ga. 30024 • 770-866-3200 • <http://www.mascertifiedgreen.com/>