

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **NUDO PRODUCTS, INC.**
1500 TAYLOR AVENUE, SPRINGFIELD, IL 62703

Category: Construction Material - Wallcovering
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program
LEED v4.1 & v5.0 ID+C, BD+C
LEED TVOC Emissions at 14-days
US-CHPS 2020 Criteria (R2022) EQ C6.1.6
*low-emitting materials
low-emitting materials
0.5 mg/m³ or less
ceiling & wall systems*

Certified Products: FRP FiberLite® Wall Panel System

Test Date: June 03, 2025 Report No.:2500322 Certificate No.: MAS2500322

Valid: June 2025 to June 2026



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. • Suwanee, Ga. 30024 • 770-866-3200 • <http://www.mascertifiedgreen.com/>