

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **K-FLEX USA**
100 K-FLEX WAY, YOUNGSVILLE, NC 27596

Category: Construction Materials - Interior Adhesives, Glues, Sealants & Coatings
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program
LEED v4.1 ID+C, BD+C
LEED TVOC Emissions at 14-days
low-emitting materials
low-emitting materials
0.5 mg/m³ or less

Certified Products: 720 LVOC

Test Date: September 15, 2025 Report No.:2500531 Certificate No.: MAS2500531-01KF

Valid: September 2025 to September 2026



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct • Suwanee, Ga. 30024 • 770-866-3200 • <http://www.mascertifiedgreen.com/>