

# MAS Certified Green® Certificate of Compliance

## Low-Emitting Materials



Awarded to: **H.B. FULLER CONSTRUCTION PRODUCTS, INC.**  
6107 INDUSTRIAL WAY, HOUSTON, TX 77011

Category: Construction Materials - Adhesives, Sealants & Coatings  
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office (duct systems only)*

\*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*  
LEED v4.1 & v5.0 ID+C, BD+C *(classroom & office setting)* *low-emitting materials*  
TVOC Emissions at 14-days *less than 0.5 mg/m³*  
US-CHPS 2020 Criteria (R2022) EQ C6.1.5 *paints & coatings*

Certified Products: Group 1: Vapor Retarder Coatings: 30-33, 30-65\*\*, 30-80, 30-80AF, 30-90, CP-33, CP-34, CP-35, CP-38 & CP-38 AF.

\*\*Product tested as representative exemplar of product bracket listed above.

Test Date: December 23, 2025 Report No.:2500717 Certificate No.: MAS2500717-01R1

**Valid: December 2025 to December 2026**



Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012  
\*outside of A2LA accreditation scope

Page 1 Of 1