



# MAS Certified Green® Certificate of Compliance

## Low-Emitting Materials

Awarded to: **DURO-DYNE CORPORATION**

81 SPENCE STREET, BAY SHORE, NY 11706

Category: Construction Materials - Interior Adhesives, Glues, Sealants & Coatings  
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

\*Conforms With: Criteria of MAS Certified Green® Program  
LEED v4.1 ID+C, BD+C  
LEED TVOC Emissions at 14-days  
CHPS 2019 Core Criteria 3.0 EQ C6.1.1

*low-emitting materials*  
*low-emitting materials*  
*0.5 mg/m<sup>3</sup> or less*  
*adhesives & sealants*

Certified Products: SGD Low VOC Adhesive

Test Date: April 24, 2025 Report No.:2500212 Certificate No.: **MAS2500212-02DD**

**Valid: April 2025 to April 2026**



Testing Cert. # 2925.01  
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017

3<sup>rd</sup> Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012

\*outside of A2LA accreditation scope

Page 1 Of 1