

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **H.B. FULLER CONSTRUCTION PRODUCTS, INC.**
6107 INDUSTRIAL WAY, HOUSTON, TX 77011

Category: Construction Materials - Adhesives, Sealants & Coatings
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program
LEED v4.1 & v5.0 ID+C, BD+C
LEED TVOC Emissions at 14-days
US-CHPS 2020 Criteria (R2022) EQ C6.1.1

low-emitting materials
low-emitting materials
0.5 mg/m³ or less
adhesives & sealants

Certified Products: Group 7: Joint Sealants: 30-45N, CP-70**.

**Product tested as representative exemplar of product bracket listed above.

Test Date: December 23, 2025 Report No.:2500717 Certificate No.: **MAS2500717-07R1**

Valid: December 2025 to December 2026



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

Page 1 of 1