

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **MPL COMPANY**
203 N. EDGERTON STREET, FAIRLAND, IN 46126

Category: Construction Materials - Cultured Marble Wall Panels and Floor Pans
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom setting, private office & residential setting*
(modeled to 2 residential showers)

*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*
LEED v4.1 & v5.0 ID+C, BD+C *low-emitting materials*
LEED TVOC Emissions at 14-days *0.5 mg/m³ or less*

Certified Products: *Tub & Shower Surrounds**, Shower Pans & Accessories.*

** Products tested as representative exemplar of products listed above.

Test Date: December 02, 2025 Report No.:2500694 Certificate No.: MAS2500694

Valid: December 2025 to December 2026



Product Certifier, MAS Certified Green CT
Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. · Suwanee, Ga. 30024 · 770-866-3200 · <http://www.mascertifiedgreen.com/>