

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **AEROFLEX USA, INC.**
282 INDUSTRIAL PARK ROAD, SWEETWATER, TN 37874

Category: Construction Materials - Exterior/Interior** Adhesives, Glues, Sealants & Coatings
Cert. Scheme: VOC Content & VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*
South Coast Air Quality Management District Rule 1168 *low VOC content-adhesives & sealant applications*

*Conforms With: Criteria of MAS Certified Green® Program *low VOC content & emissions materials*
LEED v4.1 & v5.0 ID+C, BD+C *low VOC content & emissions materials*
LEED TVOC Emissions at 14-days *0.5 mg/m³ or less*
US-CHPS 2020 Criteria (R2022) EQ 6.1.1 *adhesives & sealants*
(low VOC content & low VOC emissions)
Material VOC Content *(less water & less exempt compounds)* 249 g/L

Certified Products: Aeroseal LVOC

Test Date: February 09, 2026 (VOC content) Report No.:2600026 Certificate No.:MAS2600026-01
February 23, 2026 (VOC emissions)

Valid: February 2026 to February 2027



Product Certifier, MAS Certified Green CT

Page 1 Of 1

Lab VOC content Testing by [Applied Technical Services, LLC](#) - ISO/IEC 17025:2017 (A2LA cert. #1888.02)
Lab VOC emissions testing & 3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope
**Compliance designation determined based on interior modeling scenarios and interior VOC Emissions guideline requirements.

3945 Lakefield Ct. · Suwanee, Ga. 30024 · 770-866-3200 · <http://www.mascertifiedgreen.com/>