

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **BLUE RIDGE FIBERBOARD, INC.**
250 Celotex Drive, Danville, VA 24541

Category: Construction Material - Ceiling & Wall Panels
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom setting*
(as 4 walls or as ceiling panels)

*Conforms With: Criteria of MAS Certified Green® Program
LEED v4.1 & v5.0 ID+C, BD+C
LEED TVOC Emissions at 14-days
US-CHPS Criteria 2.0 (2020) EQ C6.1.6
low-emitting materials
low-emitting materials
0.5 mg/m³ or less
ceiling & wall systems

Certified Products: Fiberboard: **INDUSTRIAL BOARD PLAIN (IBP)**

SoundStop Acoustical Panel product tested as representative exemplar of product listed above.

Test Date: June 03, 2026 Report No.:2600201 Certificate No.: MAS2600201-02

Valid: June 2026 to June 2027



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. • Suwanee, Ga. 30024 • 770-866-3200 • <http://www.mascertifiedgreen.com/>