MAS Certified Green® Certificate of Compliance

Low-Emitting Materials

Awarded to: ***PINTURAS BEREL, SA DE CV***

Carretera a Villa de Garcia No. 2551 Km. 2.7, Santa Catarina, NL C.P. 66350 México

Category: Construction Materials – Paints & Coatings
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With:

Criteria of MAS Certified Green® Program	*low-emitting materials*
LEED v4.1 & v5.0 ID+C, BD+C	*low-emitting materials*
LEED TVOC Emissions at 14-days	*0.5 mg/m^3 or less (classroom)*
LEED TVOC Emissions at 14-days	*0.5 mg/m^3 to 5.0 mg/m^3 (private office)*
US-CHPS Criteria 2.0 (2020) EQ C6.1.5	*paints & coatings*

Certified Products: Waterbased Enamels: *Biometal***, Primario Biometal.*

**Product tested as representative exemplar of products listed above.

Test Date: June 05, 2026 Report No.:2600232 **Certificate No.: MAS2600232-03**

Valid: June 2026 to June 2027

Kevin Simpson

Digitally signed by Kevin Simpson
DN: cn=Kevin Simpson, c=US, o=Materials Analytical Services, LLC, ou=QA, email=ksimpson@mastest.com
Reason: I am approving this document
Date: 2026.06.08 12:10:47 -04'00'

Product Certifier, MAS Certified Green CT

Testing Cert. # 2925.01
Product Cert. # 2925.02

Laboratory Testing by Materials Analytical Services, LLC – ISO/IEC 17025:2017
3rd Party Product Certification by MAS Certified Green® - ISO/IEC 17065:2012
***outside of A2LA accreditation scope**

3945 Lakefield Ct. · Suwanee, Ga. 30024 · 770-866-3200 · http://www.mascertifiedgreen.com/