

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **HERCULES INDUSTRIES, INC.**
1310 W. EVANS AVENUE, DENVER, CO 80223

Category: Construction Materials - Interior Adhesives, Glues, Sealants & Coatings
Cert. Scheme: VOC Emissions, **VOC Content

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*
SCAQMD Rule 1168 (**VOC Content) *adhesive & sealant applications*

*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*
LEED v4.1 & v5.0 ID+C, BD+C (VOC Emissions & Content) *low-emitting materials*
LEED TVOC Emissions at 14-days *0.5 mg/m³ or less*
US-CHPS Criteria 2.0 (2020) EQ C6.1.1 *adhesives & sealants*
Total VOC Content (less water) *6.0%, 69.0 g/L*

Certified Products: Duct Liner Adhesives: MTA500, MTA600, MTA600W***.
(*** Product tested as representative exemplar of products listed above.)

Test Date: July 27, 2026 Report No.: 2600297 Certificate No.: MAS2600297-02

Valid: July 2026 to August 2027



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

**Laboratory Testing by [ATS Labs, Marietta GA, 30062](#) - ISO/IEC 17025:2017 (#1888.02)

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017

Page 1 Of 1

3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

3945 Lakefield Ct. • Suwanee, Ga. 30024 • 770-866-3200 • <http://www.mascertifiedgreen.com/>