

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **SOLAR GARD® SAINT GOBAIN**
4540 VIEWRIDGE AVENUE, SAN DIEGO, CA: 92123

Category: Construction Materials - Thermal Window Films
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program
LEED v4.1 & v5.0 ID+C, BD+C
LEED TVOC Emissions at 14-days
low-emitting materials
low-emitting materials
0.5 mg/m³ or less

Certified Products: Solar Gard® Window Films with Pressure Sensitive Adhesive
Solar Gard® Safety Window Films with Pressure Sensitive Adhesive
Solar Gard® Anti-Graffiti/Vandalism Window Films with Pressure Sensitive Adhesive**

** Product tested as representative exemplar of products listed above.

Test Date: July 02, 2026 Report No.: 2600261 Certificate No.: MAS2600261

Valid: July 2026 to July 2027



Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. · Suwanee, Ga. 30024 · 770-866-3200 · <http://www.mascertifiedgreen.com/>