MAS Certified Green® Certificate of Compliance
Low-Emitting Materials

Awarded to: **LUXE SURFACES**
10028 Maumelle Boulevard, Little Rock, AR 72113

Category:	Construction Material – Wallcovering	
Cert. Scheme:	VOC Emissions	
Accredited Standards & Test Methods:	California Dept. of Public Health Standard Method v1.2	*classroom & private office*
*Conforms With:	Criteria of MAS Certified Green® Program	*low-emitting materials*
	LEED v4.1 & v5.0 ID+C, BD+C	*low-emitting materials*
	LEED TVOC Emissions at 14-days	*0.5 mg/m³ or less*
	US-CHPS Criteria 2.0 (2020) EQ C6.1.6	*ceiling & wall systems*
Certified Products:	*Patty Madden Real Wood Veneer™ Wallcovering Natural and Reconstituted Wood Veneers by Luxe Surfaces*	

Test Date: February 26, 2026 Report No.:2600028 **Certificate No.: MAS2600028-LSR1**

Valid: March 2026 to March 2027

Kevin Simpson
Digitally signed by Kevin Simpson
DN: cn=Kevin Simpson, c=US, o=Materials Analytical Services, LLC, ou=QA, email=ksimpson@mastest.com
Reason: I am approving this document
Date: 2026.09.01 13:28:24 -04'00'

Product Certifier, MAS Certified Green CT

Testing Cert. # 2925.01
Product Cert. # 2925.02

Laboratory Testing by Materials Analytical Services, LLC – ISO/IEC 17025:2017
3rd Party Product Certification by MAS Certified Green® - ISO/IEC 17065:2012
***outside of A2LA accreditation scope**

3945 Lakefield Ct. · Suwanee, Ga. 30024· 770-866-3200 · http://www.mascertifiedgreen.com/